

# Control Scheme For Multiterminal Hybrid Power System

**Sugi R.**

*Department of EEE, Adhiyamaan College of Engineerin  
Hosur 635 109, Tamilnadu, India*

**Sundararajan D.**

*Department of EEE, Adhiyamaan College of Engineering  
Hosur 635 109, Tamilnadu, India.*

## Abstract

In this paper, we investigate an event based protection scheme for dc power system which includes hybrid energy sources. The proposed protection scheme requires less time when compared with other methods. In this method, fault can be isolated and efficiency can be improved. The performance of protection scheme was evaluated under the transmission lines.

**Index terms-** Voltage boost up, Fault identification, multilevel inverter, battery, Fuel cell.


## I. INTRODUCTION

A hybrid DC power system is more reliable with high efficiency through by using hybrid energy source. However it protect the system from phase to ground fault in multiterminal hybrid DC power system.

This paper provides simple and efficient technics for a multiterminal DC power system. In various applications such as telecommunication system and distribution system involving large number of electronic loads which provide effective solution for power distribution [1]. The DC microgrids, coordinate operation of power converters and mechanical contactor can rapidly isolate the short circuit faults. However, there is a concern to protect the system from short circuit faults [2]. Event based protection scheme recently developed for AC power system [3]. The transient short circuit current contain high frequency oscillation which may cause alising error and saturate the analog to digital converters [4]. The load voltage can be maintained by the ultracapacitor hybrid energy storage system [5]. The power system protection

includes large number of buses and feeders [7]-[9]. The protection unit is able to identify the type of event using current derivative fault identification method. Event based protection scheme has as a single alternate power supply. The performance of the event based protection scheme was evaluated under different DC feeder and bus fault. Since it is difficult to identify an interconnected feeder fault from a bus fault or an adjacent feeder fault [11]. Figure 1 shows the fault protection scheme in a multiterminal hybrid power system. The fault protection scheme can improve the efficiency using multiterminal hybrid DC power system. Here each phase can be able to identify the fault simultaneously.

## II. HYBRID ENERGY SOURCE




**Figure 1:** Proposed protection scheme for a multiterminal hybrid power system


The proposed scheme consist of hybrid energy source such as fuel cell and battery. When the fault has been occur, the voltage may drop. The fuel cell and battery can be increase the voltage level. The hybrid DC source can be connected to multilevel inventor and then given to the power supply.

### A. Energy storage system

Battery and fuel cell was used as an alternate power supply. A fuel cell was implemented as an energy storage system. The fuel cell composed of operating temperature  $65^{\circ}\text{C}$ , pressure 1.5 and Hydrogen composition 99.95 %, the voltage and current value can be given in the fig 2. The flow rate, utilization of hydrogen and oxygen stack consumption and stack efficiency is shown in fig 3. The fuel cell converts chemical energy into electrical energy.



**Figure 2:** Voltage and current waveform for fuel consumption



**Figure 3:** Flow rate of Hydrogen consumption


For the three phase system the hybrid energy source can be given as separately to improve the efficiency.

**B. Multiterminal Inverter**

The multiterminal inverter is to boost up the voltage when there is a sudden change in the voltage. The fault protection scheme consists of three multiterminal inverter. Each inverter has eight MOSFETs.

### III. FAULT ISOLATION


When there is a phase to ground fault in a transmission line, the voltage sag and swell may occur during the time period  $t = 0.2s$ .



**Figure 4:** Voltage and current waveform with fault

Figure 4 shows the voltage and current waveform when the fault has been occur during the time of fault voltage sag and swell may occur.

Figure 5 shows the active and reactive power waveform when the fault has been occur during the time of fault voltage sag and swell may occur.




**Figure 5:** Active power and reactive power waveform

### IV. FAULT PROTECTION SCHEME


When the fault occur, the voltage sag and swell is increased. Here, the hybrid power system fuel cell and battery supplies power when there is a voltage drop, this will increase the voltage level.

The voltage and current waveform during after the fault period is shown in Figure 6.



**Figure 6:** Voltage and Current Waveform after Fault period

Figure 7 shows the active and reactive power after the occurrence of fault.



**Figure 7:** Active and reactive power waveform at the time of fault condition

## V. CONCLUSION

An event based protection scheme for a multiterminal hybrid DC power system was investigated. The model for a multiterminal hybrid DC power system was implemented in the MAT LAB/Simulink.

In the proposed protection strategy, each phase has an alternate supply when the fault has been has been occurred. Then the voltage can be increased by using the alternate supply. In the proposed protection scheme efficiency has been increased.

**REFERENCES**

- [1] M. Farhadi and O. Mohammed, "Real-time operation and harmonic analysis of isolated and non-isolated hybrid DC microgrid", *IEEE Trans. Ind. Appl.*, vol. 50, no. 4, pp. 2900-290, Jul./Aug. 2014.
- [2] P. Cairoli, I. Kondratiev, and R. A. Dougal, "Coordinated control of the bus tie switches and power supply converters for fault protection in DC microgrid", *IEEE Trans. Power Electron.*, vol. 28, no. 4, pp.2037-2047, Apr. 2013.
- [3] Y. Pradeep, S. Khaparde, and R. Jhoshi, "High level event ontology for multi area power system," *IEEE Trans. Smart Grid*, vol. 3, no. 1, pp. 193-202, Mar. 2012.
- [4] S.R. Velaquez, T.Q. Nguyen, and S.R. Broadstone, "Design of hybrid filter banks for analog/digital conversion," *IEEE Trans. Signal process.*, vol. 46, no. 4, pp. 956-967, Apr. 1998.
- [5] J. Cao and A. Emadi, "A new battery/ultracapacitor hybrid energy storage system for electric, hybrid, and plug in hybrid electric vehicles", *IEEE Trans. Power Electron.*, vol. 27, no. 1, pp. 122-132, Jan. 2012.
- [6] A. Mohaned, C. Cossio, T. Ma, M. Farhadi, and O. Mohammed, "Operation and protection of photovoltaic systems in hybrid AC/DC smart grid," in proc. *IEEE 38<sup>th</sup> Annu. Conf. IEEE Ind. Electron. Soc. (IECON)* Montreal, QC, Canada, 2012, pp. 1104-1109.
- [7] D.Salomonsson, L. Soder, and A. Sannino, "Protection of low-voltage DC microgrids", *IEEE Trans. Power del.*, vol. 24 no. 3, pp. 1045-1053, Jul. 2009.
- [8] L. Tang and B. T. Ooi, "Locating and isolating DC faults in multiterminal DC system", *IEEE Trans. Power Del.*, vol. 22, no. 3, pp. 1877-1884, Jul. 2007.
- [9] F. Lotfifard, H. Seifi, and M. K. Sheikh-El-Eslami, "An economic-based special protection system in a restructured environment", *Elect. Power compon. Syst. J.*, vol. 41 no. 15, pp. 1536-1554, 2013.
- [10] M. Farhadi and O. Mohammed, "Adaptive energy management in redundant hybrid DC microgrid for pulse load mitigation", *IEEE Trans. Smart Grid*, vol. 6, no. 1, pp.54-62, Jan. 2015.
- [11] Mustafa Farhadi and Osama A. Mohammed, "Event based protection scheme for a multiterminal hybrid DC power system", *IEEE Trans. Smart grid.*, vol. 6, no 4, July 2015.